

# Safe Distance for Moving Equipment and Buildings Under Power Lines

(If your equipment, buildings, or objects exceed the heights in the chart below, you must contact your electrical service provider before proceeding)

- 3.6 metres for pedestrian areas
- 4.1 metres for driveways
- 4.2 metres for agricultural areas
- 4.3 metres underground pipelines
- 4.8 metres for alleys, commercial premises
- 5.3 metres for roads

